



ARVIN PARSHALL FLUME PROJECT  
ADDENDUM 1

Issue Date: September 25, 2018

Below is a compilation of Request for Information (RFI) / Request for Clarifications received from interested bidders and our responses to the RFI/RFCs:

**Question #1:**

Please see the following request for clarification in regards to the above captioned project set to bid on October 2, 2018:

Per the Instructions to Bidders, Section 13.14 requires the bidder to indicate in the appropriate space provided in the bid form cost of insurance premiums for earthquake and tidal wave to indemnify Owner for damage of the Work caused by earthquake or tidal wave in an amount of at least 50 percent of the contract price. Please confirm that coverage for Acts of God as defined in California PCC 7105 is not required as there is not a separate line item in the bid forms.

**Response**

*Confirmed. Coverage for Acts of God as defined in California PCC 7105 is not required.*

**Question #2:**

Per the Supplementary Conditions, 5.06E, requires the Contractor to purchase and maintain Builder's Risk "all-risk" insurance coverage including earthquake. Pursuant to PCC 7105, Contractors are not responsible to the public agency for repairing or restoring damages caused by an act of God in excess of 5% of the contracted amount. If insurance is required to cover acts of God as they are defined (earthquake in excess of 3.5 on the Richter Scale and tidal waves), a separate bid item for this coverage is required. Please confirm the requirement for such policy shall exclude Acts of God as defined in PCC 7105.

**Response**

*Confirmed. Contractors are not required to the public agency for repairing or restoring damages caused by an act of God in excess of 5% of the contracted amount pursuant to PCC 7105.*

**Question #3:**

Contract Drawing 6 calls for a 12" FRP parshall flume. Specification Section 06611-2.03C indicates a width of 24". Please confirm the size of the parshall flume.

**Response:**

*We confirm, the size of Parshall Flume required is 6" (six inches) FRP.*